



Paul R. LePage, Governor

Mary C. Mayhew, Commissioner

Tel. (207) 287-5672

Fax (207) 287-4172

Department of Health and Human Services
Maine Center for Disease Control and Prevention
286 Water Street
11 State House Station
Augusta, Maine 04333-0011
Tel.: (207) 287-8016; Fax: (207) 287-9058
TTY Users: Dial 711 (Maine Relay)

Subsurface Wastewater Unit

December 3, 2012

SYMPCO, LLC
Attn.: Robert F. Silva, VP
P. O. Box 2217
South Portland, ME 04106

Subject: Product Registration, Norweco Inc., Singulair Model 960 and Model TNT-500

Dear Mr. Silva:

The Division of Environmental Health has completed a review of a registration application for the subject products. This information was submitted pursuant to Section 6.HH of the Subsurface Wastewater Disposal Rules for registration for use in Maine.

The Norweco Inc., Singulair Model 960 and Model TNT-500 each consist of a multiple compartment treatment tank with primary, secondary, and clarification chambers. According to the information you provided, the Norweco Inc., Singulair Model 960 and Model TNT-500 have been certified by the National Sanitation Foundation (NSF) pursuant to ANSI/NSF Standard 40 for residential wastewater treatment systems, for reductions in organic loading and nitrogen. You have requested that the disposal area size be allowed to be reduced to 75 percent of the normal size required by the Rules, when used in conjunction with stone and pipe disposal trenches.

On the basis of the information, the Division has determined that the Norweco Inc., Singulair Model 960 and Model TNT-500 is acceptable for use in the State of Maine, provided that it is installed, operated, and maintained in conformance with the manufacturer's directions. The disposal area may be reduced to 75 percent of the normal size required by the Rules, when used in conjunction with stone and pipe disposal trenches.

Because installation and owner maintenance has a significant effect on the working order of onsite sewage disposal systems, including their components, the Division makes no representation or guarantee as to the efficiency and/or operation of Norweco Inc., Singulair Model 960 and Model TNT-500. Further, registration of this product for use in the State of Maine does not represent Division preference or recommendation for this product over similar or competing products.

If you have any questions please feel free to contact me at (207) 287-5695.

Sincerely,

James A. Jacobsen
Project Manager, Webmaster
Division of Environmental Health
Drinking Water Program
Subsurface Wastewater Unit
e-mail: james.jacobsen@maine.gov

/jj

xc: Singulair Product File