


NOTES:

1. CONCRETE: 5,000 PSI MIN AFTER 28 DAYS.
2. TYPE III CEMENT.
3. TEST BAFFLES SOLD SEPARATELY.
4. 4" POLYLOK IV CLOSED END BOOTS USED FOR CONNECTIONS.
5. JOINT SEALED WITH BUTYLE RESIN.
6. PUMPS & ACCESSORIES OPTIONAL
7. PLASTIC RISER CAN BE POURED INTO COVER.

			PREPARED FOR: ANDREW J. FOSS CO. INC.		
			100 COCHECO ROAD FARMINGTON, NH 03835		
			PHONE(603)755-2515 FAX(603)278-7878		
REV.NO.	DATE	REVISION	DATE: 9/18/09	SHEET TITLE: SKETCH	DRWN BY: GJP
			SCALE: N.T.S.	CKD BY:	
PREPARED BY:			PROJECT: 4' x 4'-6" PUMP BOX		
 DELTA ENGINEERS, ARCHITECTS, & LAND SURVEYORS 184 COURT STREET, BINGHAMTON, NY 13901 TEL: (607) 231-6600 FAX: (607) 231-6650			CONTRACTOR:		DWG. I.D. SK-01
			DELTA PROJ. NO.: 2009.367.001		SHT. NO. 1 OF 1