



- NOTES:
1. CONCRETE: 5,000PSI MIN AFTER 28 DAYS.
  2. ALL REINFORCEMENT PER ASTM C1227-93.
  3. TEES AND GAS BAFFLE SOLD SEPARATELY.
  4. TONGUE & GROOVE JOINT SEALED WITH BUTYLE RESIN.
  5. 4" POLYLOK IV CLOSED END BOOTS USED FOR CONNECTIONS.
  6. PLASTIC RISER CAN BE POURED INTO COVER.

			PREPARED FOR:	
			<b>ANDREW J. FOSS CO. INC.</b>	
			100 COCHECO ROAD FARMINGTON, NH 03835	
			PHONE(603)755-2515 FAX(603)278-7878	
REV.NO.	DATE	REVISION		
PREPARED BY:			DATE: 9/16/09	SHEET TITLE: SKETCH
<b>DELTA</b> ENGINEERS, ARCHITECTS, & LAND SURVEYORS 184 COURT STREET, BINGHAMTON, NY 13901 TEL: (607) 231-6600 FAX: (607) 231-6650			SCALE: N.T.S.	DRWN BY: GJP
			PROJECT: 1000 GALLON TANK H-20	
			CONTRACTOR:	DWG. I.D. SK-01
			DELTA PROJ. NO.: 2009.367.001	SHT. NO. 1 OF 1