



- NOTES:
1. CONCRETE: 5,000PSI MIN AFTER 28 DAYS.
  2. ALL REINFORCEMENT PER ASTM C1227-93.
  3. TEES AND GAS BAFFLE SOLD SEPARATELY.
  4. TONGUE & GROOVE JOINT SEALED WITH BUTYLE RESIN.
  5. 4" POLYLOK IV CLOSED END BOOTS USED FOR CONNECTIONS.
  6. PLASTIC RISER CAN BE POURED INTO COVER.

REV. NO.    DATE    REVISION			PREPARED FOR: <b>ANDREW J. FOSS CO. INC.</b> 100 COCHECO ROAD FARMINGTON, NH 03835 PHONE (603) 755-2515    FAX (603) 278-7878		
PREPARED BY: <b>DELTA</b> ENGINEERS, ARCHITECTS, & LAND SURVEYORS 184 COURT STREET, BINGHAMTON, NY 13901 TEL: (607) 231-6800    FAX: (607) 231-6850			DATE: 9/16/09 SCALE: N.T.S.	SHEET TITLE: <b>SKETCH</b>	DRWN BY: GJP CKD BY: KMK
PROJECT: <b>1500 GALLON TANK H-20</b>			CONTRACTOR: DELTA PROJ. NO.: 2009.367.001		
			DWG. I.D.: SK-01 SHT. NO.: 1 OF 1		