



- NOTES:
1. CONCRETE: 5,000PSI MIN AFTER 28 DAYS.
  2. ALL REINFORCEMENT PER ASTM C1227-93.
  3. TEES AND GAS BAFFLE SOLD SEPARATELY.
  4. TONGUE & GROOVE JOINT SEALED WITH BUTYLE RESIN.
  5. 4" POLYLOK IV CLOSED END BOOTS USED FOR CONNECTIONS.
  6. PLASTIC RISER CAN BE POURED INTO COVER.
  7. PUMPS & ACCESSORIES OPTIONAL.

	PREPARED FOR: <b>ANDREW J. FOSS CO. INC.</b> 100 COCHECO ROAD FARMINGTON, NH 03835 PHONE(603)755-2515 FAX(603)278-7878		
	REV. NO. _____	DATE _____	REVISION _____
PREPARED BY: <div style="text-align: center;"> <p><b>DELTA</b>            ENGINEERS, ARCHITECTS, &amp; LAND SURVEYORS            184 COURT STREET, BINGHAMTON, NY 13901            TEL: (607) 231-6800 FAX: (607) 231-6850</p> </div>			
DATE: 9/16/09		SHEET TITLE: <b>SKETCH</b>	DRWN BY: GJP
SCALE: N.T.S.		CKD BY: KMK	
PROJECT: 2639 GALLON TANK 464 GALLON CHAMBER H-20			
CONTRACTOR:		DWG. I.D. SK-01	SHT. NO. 1 OF 1
DELTA PROJ. NO.: 2009.367.001			